PRICE SCHEDULE

Tender for the Supply of 450mm dia Non Raising sluice valve (PN 25) to delivery side of pumps in CWSS Stage 1 & 2 Pumping stations at TK Halli .

SL No.	Specifications	Unit	Qty	Rate	Amount
1	Supply of 450mm dia sluice type Metal seated sluice valve/gate valve as per IS: 14846 PN 25 rating with hand wheel operated. **Material of Construction**: Body/Bonnet/Wedge of Ductile Iron to IS 1865 Gr.400/15 or superior grade, Spindle in SS AISI 410, Body seat ring and wedge seat ring with Integral seat of bronze, Spindle nut of Leaded bronze, Fasteners in carbon steel IS 1367 CL 4.6/4.0 with gear box unit. Flange drilling is according to BS-4504/EN 1092. Painting epoxy powder coating. Valves suitable for a working pressure of 25kg/cm² (Seat test) and body tested to 37.5Kg/cm² shall be confirmed to IS standards	No.	8.		

↑ But Excluding GST.

Note: The rate shall be inclusive of all applicable taxes & duties, insurance, transportation, Loading & Unloading and any incidentals

AE

EE (K-O&M)-1

Executive Engineer
Kaveri -Operation & Maintenance-1
BWSSB T.K. Halli-571421

A Draft Tender papers from page no-1 to page no. (44) along with price Schedule for the "work of Supply of 450mm dia Non raising Sluice valve (PN25) to delivery Side of pumps in CWSS stage-I & II pumping stations at T.K. Halli" is Approved as corrected.

Additional Chief Engineer
(Kaveri-O&M)-1,
Bangalore Water Supply

Chief Engineer
(Kaveri -Operation & Maintainance)
BWSSB, 6th Floor,
Cauvery Bhavan, K.G. Road,